6 Du Plooy str Potchefstroom 2531 admin1@envirocare.co.za Tel: 0182944283 Cell: 0847906971/0710334843



FINAL TEST REPORT

Company:	Client:	Contact Number:	Email:	Address:
Afriforum Parys	Alta Pretorius	081 392 2071	alta.pretorius@afriforum.co.za	c/o DF Malan ave & Union weg, Centurion, 0157

Result Information

Order number:	Order Placed:	Analysis started:	Completion:
230523-14	2023/05/23	2023/05/23	2023/05/25
Samples received Date	Sampler:	Sample Site:	Report Reference:
Samples received Date:	Sampler.	Sample Site.	Report Reference.

Sample Condition:

7°C

Test Result: Water

	Samples				
Analysis	Water Treatment After Chlorination Outflow 23/05/2023 12:15	Uni Straat 33A Drink Water Netwerk Kraan 23/05/2023 13:02	Downstream Of Sewage Spill Vaalrivier 23/05/2023 13:22		
Total Plate Count TEC-08 Cfu/ml	19	57	>30 000		
Total Coliforms TEC-27 Cfu/100ml	<1	22	>80		
Escherichia coli TEC-27 Cfu/100ml	<1	<1	>80		
Faecal Coliforms TEC-10 Cfu/100ml	<1	<1	>80		
*Vibrio Cholera TEC-35 Present/Absent/10ml	Absent	Absent	Present		

Abbreviations and remarks:

CFU: Colony Forming Units

<1 / <10 : None Detected

- Envirocare endeavours to perform correct analyses.
- Results relate only to the sample as received by the laboratory. When samples are supplied by the customer, the customer is
 responsible for correct sampling techniques and sample identification.
- Results identified with a "*" in this report are not included in the SANAS schedule of accreditation for this Laboratory. Results identified with a "#" in this report are sub-contracted for the required analysis.
- Opinions and interpretations expressed in this report are based upon analysis of the sample as received and the subsequent results achieved.



Technical signatory

End of Report

